

Aksenov Andrey Igorevich
 General Director
 IXcellerate 3 Limited Liability Company
 33B, 2nd Floor, Office IV/5, Altufyevskoe Av.
 Moscow 127410
 Russia

18 November 2025



Tier III Certification of Design Documents for IXcellerate 3 Limited Liability Company – IXcellerate MOS5.4 and MOS5.5 in Moscow, Russia

Dear Aksenov Andrey Igorevich,

Uptime Institute Professional Services is pleased to announce the Tier Certification of Design Documents for the IXcellerate 3 Limited Liability Company – IXcellerate Moscow South 5.4 (MOS5.4) and Moscow South 5.5 (MOS5.5) as fulfilling Tier III Concurrently Maintainable criteria. This Certification is based upon the design documentation submitted between 4 July and 24 October 2025.

This Certification recognizes that IXcellerate 3 Limited Liability Company – IXcellerate MOS5.4 and MOS5.5 is capable of supporting any planned work on the site infrastructure without disrupting more than the redundant computer room power and cooling capacity. This Tier III Certification is limited by the stated total peak IT load of 14,220 kilowatts (kW). This includes a 2,988-kW IT load in Data Hall M5.41; a 3,510-kW IT load in Data Hall M5.42; a 3,312-kW IT load in Data Hall M5.51; and a 4,410-kW IT load in Data Hall M5.52.

Tier III Concurrently Maintainable criteria are founded on the capability to complete planned facility maintenance or modifications on a scheduled basis; equipment failures or distribution path faults may lead to unplanned outages. Certain operator errors, such as procedural errors during reconfiguration of the redundant computer room or site infrastructure equipment, may also impact the critical load.

This Tier Certification is based on the 100% design documents as submitted for review and makes no assurances as to the constructed environment. This Tier Certification is valid until the design is modified, including any changes to the capacity components or distribution paths depicted in the design identified above and submitted for review. This Certification is subject to the limitations set forth in Schedule I, attached hereto and incorporated herein.

The Tier III Certification of Design Documents award is valid until 18 November 2027 subject to the limitations and extension request process set forth in the attached Schedule I.

Congratulations on this achievement.

Sincerely,



Christopher Brown
 Chief Technical Officer